

ASBESTOS MANAGEMENT PLAN

Location No.	Sample No.	Location	Area Surveyed	Position	Product	Asbestos type	Quantity	Surface	Vulnerability	Condition	Materials Risk Ass.	Priority
1	1	Ground Floor	Gym	Ceiling tiles	Asbestos Insulating Board	Amosite	50m ²	Unsealed	High	Good	6	1
2	2	Ground Floor	Main Hall	Ceiling tiles	Asbestos Insulating Board	Amosite	100m ²	Unsealed	Low	Good	6	3
3	3	Ground Floor	Kitchen	Red floor tiles	Asbestos Vinyl Tiles	Chrysotile	100m ²	Sealed	Medium	Good	1	2

Priority Rating:
1 = Take out/remove
2 = Encapsulate/seal/treat
3 = Leave it

Date:.....

Signed:.....